

**CITY OF NEW ROCHELLE**  
**DEPARTMENT OF PUBLIC WORKS - ENGINEERING**  
**EPA 02-2015 -3034 CHURCH STREET OUTFALL & STORM DRAIN SAMPLING**

NY Water Quality Standards = 2,000 MPN/ 100ml Fecal & 10,000 MPN/ 100ml Total Coliform

LOCATION	SAMPLE DATE	LAB SAMPLE RESULTS		Discharge Ratings Obvious/Suspect/ Potential/Unlikely
		FECAL PER 100 ml	COLIFORM PER 100 ml	
SAMPLES OF ISAAC YOUNG JUNIOR HIGH SCHOOL				
SDMH # 1A CHURCH ST IYMS FLOW (BOTTLE # 3521)	10/11/2016	79,000	110,000	Potential
SDMH # 4A IFO # 34 TRINITY PLACE (BOTTLE # 2971)	10/11/2016	790	9,200	Unlikely
SDMH # 5A 200 CENTRE AVE PARKING SPOT NO. 40 (BOTTLE # 2934)	10/11/2016	330	6,400	Unlikely
SDMH # 7A CORNER WALL OF BASEBALL IYMS PARKING SPOT (BOTTLE # 1815)	10/13/2016	1,700	4,000	Unlikely